

# ITS.SC.520 Temperature and Humidity Controls



Approved Sept. 10th, 2020  
Next Scheduled Review: Sept. 10th, 2025

---

## Procedure Statement

---

Texas A&M University-Kingsville (TAMUK) maintains optimal temperature and humidity levels within the University data center facility where all production information systems reside and monitors temperature and humidity levels as required to maintain operations

---

## Reason for Procedure

---

This Control applies to all TAMUK network information resources. The intended audience for this Control includes all information resource owners, custodians, and users of information resources.

External and/or environmental threats (e.g., fire, flood, earthquake, civil unrest) disrupt operations due to inadequate physical security controls.

---

## Procedures and Responsibilities

---

Information resource owners with responsibility over infrastructure equipment shall monitor temperature and humidity levels on a continuous (24/7) basis and employ temperature and humidity monitoring that provides an alarm or notification of changes potentially harmful to personnel or equipment

---

## Related Statutes, Policies, Rules or Requirements

- 
- 1.) DIR Practices for Protecting Information Resources Assets
- 

## Contact Office

---

For More Information, Contact: ITS  
MSC 185, 700 University Blvd., Kingsville, TX 78363-8202  
Contact Phone: 361-593-2404